

Certificate of Approval

This certificate confirms that the company below complies with the following standard(s):

Company Name	AMPAC Safety Pty Ltd	Client ID	103379
Company Other Name		Type of Certification	Product Certification; System 5
Certification Standard	AS/NZS 1841.5-2007 : Portable fire extinguishers - Specific requirements for powder type extinguishers		
Scheme	Global-Mark Product Conformance Scheme		
Certification Review Date	20/01/2016	Certification Expiry Date	10/11/2020
Certificate Issue Date	2/02/2016	Certificate Last Update Date	19/04/2018

APPROVED COMPANY/SITE ADDRESS(ES):

7 Ledger Road Balcatta, Perth 6021 WA Australia
Wucheyan Huangjiang Town Yuyao - Zhejiang China

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Approval remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager



Unique Certificate Code: **9610DE56E1AC18BFCA25827200498BAE**

Global-Mark Pty Ltd, 407, 32 Delhi Road, North Ryde NSW 2113, Australia - Copyright 2005



Global-Mark.com.au®





global-mark®

Model(s) on which the Global-Mark logo may be applied by the certificate holder as a declaration of compliance by the certificate holder:

In placing the authorised mark on the product, the certificate holder makes a declaration of compliance with the certification standard(s) and confirms that the product is identical to the product certified herein. In issuing this Certificate of Approval Global-Mark has relied on the expertise of external bodies (laboratories, and technical experts).

Model Identification	Model Name	Brand Name	Product Description/Attributes	Date Approved
1000-1001	1.0kg ABE Powder	AMPAC	1.0 Kg Dry Powder, Rating: 1A:10B:E, FERN: 3379.05-01	17/04/2018
1000-1002	1.5kg ABE Powder	AMPAC	1.5 Kg Dry Powder, Rating: 2A:20B:E, FERN: 3379.05-02	17/04/2018
1000-1003	2.0kg ABE Powder	AMPAC	2.0 Kg Dry Powder, Rating: 2A:30B:E, FERN: 3379.05-03	17/04/2018
1000-1004	2.5kg ABE Powder	AMPAC	2.5 Kg Dry Powder, Rating: 2A:40B:E, FERN: 3379.05-04	17/04/2018
1000-1005	4.5kg ABE Powder	AMPAC	4.5 Kg Dry Powder, Rating: 4A:60B:E, FERN: 3379.05-05	17/04/2018
1000-1007	9.0kg ABE Powder	AMPAC	9.0 Kg Dry Powder, Rating: 6A:80B:E, FERN: 3379.05-06	17/04/2018

Comments:

End of the document



Certification Manager